

TEST DATE: Monday, October 4, 2021

BLOCK	MODULE	BEFORE TEST	AFTER TEST	VOLTAGE DROP
1	1	7.81	7.46	0.35
	2	7.82	7.45	0.37
2	3	7.84	7.45	0.39
	4	7.84	7.44	0.40
3	5	7.84	7.37	0.47
	6	7.84	7.46	0.38
4	7	7.84	7.40	0.44
	8	7.84	7.45	0.39
5	9	7.84	7.40	0.44
	10	7.85	7.45	0.40
6	11	7.84	7.44	0.40
	12	7.84	7.43	0.41
7	13	7.84	7.39	0.45
	14	7.84	7.39	0.45
8	15	7.85	7.40	0.45
	16	7.84	7.37	0.47
9	17	7.84	7.40	0.44
	18	7.84	7.27	0.57
10	19	8.06	7.44	0.62
	20	7.85	7.44	0.41
11	21	7.85	7.36	0.49
	22	7.85	7.43	0.42
12	23	7.84	7.42	0.42
	24	7.86	7.42	0.44
13	25	7.87	7.46	0.41
	26	7.80	7.39	0.41
14	27	7.82	7.45	0.37
	28	7.84	7.44	0.40

	block before load test	block after load test
1	15.63	14.91
2	15.68	14.89
3	15.68	14.83
4	15.68	14.85
5	15.69	14.85
6	15.68	14.87
7	15.68	14.78
8	15.69	14.77
9	15.68	14.67
10	15.91	14.88
11	15.70	14.79
12	15.70	14.84
13	15.67	14.85
14	15.66	14.89