

		TEST DATE: Sunday, November 28, 2021		5A load 2 MINS			
BLOCK	MODULE	BEFORE TEST	AFTER TEST	VOLTAGE DROP	block before load test	block after load test	
1	1	7.94	7.52	0.42	1	15.88	15.07
	2	7.94	7.55	0.39			
2	3	7.92	7.50	0.42	2	15.85	15.02
	4	7.93	7.52	0.41			
3	5	7.92	7.51	0.41	3	15.84	15.01
	6	7.92	7.50	0.42			
4	7	7.92	7.45	0.47	4	15.84	14.85
	8	7.92	7.40	0.52			
5	9	7.92	7.48	0.44	5	15.82	15.01
	10	7.90	7.53	0.37			
6	11	7.91	7.48	0.43	6	15.81	14.99
	12	7.90	7.51	0.39			
7	13	7.91	7.41	0.50	7	15.82	14.76
	14	7.91	7.35	0.56			
8	15	7.90	7.48	0.42	8	15.80	15.02
	16	7.90	7.54	0.36			
9	17	7.90	7.50	0.40	9	15.80	15.04
	18	7.90	7.54	0.36			
10	19	7.90	7.48	0.42	10	15.81	15.00
	20	7.91	7.52	0.39			
11	21	7.92	7.46	0.46	11	15.83	14.98
	22	7.91	7.52	0.39			
12	23	7.91	7.47	0.44	12	15.83	15.00
	24	7.92	7.53	0.39			
13	25	7.91	7.47	0.44	13	15.83	15.00
	26	7.92	7.53	0.39			
14	27	7.93	7.51	0.42	14	15.89	15.01
	28	7.96	7.50	0.46			